



## TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and  
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 7490/RFL/NMSB/2025

Dated: 20/05/2025

District Office,  
Fire and Rescue Service,  
Tirunelveli District.

### RENEWAL OF FIRE LICENSE

Ref: Letter no:287159 from the M/s.PSN YAMUNA LADIES  
HOSTEL, Melathidiyoor, Palayamkottai Taluk, Tirunelveli  
District, Dated: 15/05/2025

\*\*\*\*\*

The Fire License is hereby **issued** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for Hostel Building in the name of PSN Yamuna Ladies Hostel, R.S.No.4/1 pt, 4/2 pt, 4/3 pt, 4/5 A, 4/5B, 4/6B, 5/1 pt, 5/2 pt, 5/3 pt, 5/4 pt, 6/2 pt, 6/3 pt, 6/4 pt, 6/5 pt, Melathidiyoor, Palyamkottai Taluk, Tirunelveli District. Consisting of Ground Floor and Three floors within the jurisdiction of Palayamkottai based on the inspection was done by the Assistant District Officer, Palayamkottai on 15/05/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEARS** from the date of issue.

### CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do"s & Don"ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per IS 1646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid

Signed by: District Officer  
Tirunelveli  
Southern Region - District Officer,  
Date:20-May-2025 17:56:31

District Officer,

Fire and Rescue Services

Tirunelveli District



To: PSN Yamuna Ladies Hostel, R.S.No.4/1 pt, 4/2 pt, 4/3 pt, 4/5 A, 4/5B, 4/6B, 5/1 pt, 5/2 pt, 5/3 pt, 5/4 pt, 6/2 pt, 6/3 pt, 6/4 pt, 6/5 pt, Melathidiyoor, Palyamkottai Taluk, Tirunelveli District.

**Signature valid**

Signed by: District Officer  
Tirunelveli,  
Southern Region - District Officer,  
Home Department  
Date:20-May-2025 17:56:31



**TAMIL NADU FIRE AND RESCUE SERVICES**

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

**Licence No: 2214/RFL/NMSB/2025**

Dated: 20/05/2025

District Office,  
Fire and Rescue Service,  
Tirunelveli District.

**RENEWAL OF FIRE LICENSE**

Ref: Token ID: 287837 from the PSN Kamaraj Gents Hostel, Melathediyoor, Palayamkottai Taluk, Tirunelveli District Dated: 15/05/2025

\*\*\*\*\*


The Fire License is hereby issued under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for Hostel Building in the Name of PSN Kamaraj Gents Hostel, Campus of PSN Institute of Technology & Science, R.S.No.4/1pt, 4/2pt, 4/3pt, 4/5A, 4/5B, 4/6B, 5/1pt, 5/2pt, 5/3pt, 5/4pt, 6/2pt, 6/3pt, 6/4pt, 6/5pt. Melathediyoor, Palayamkottai Taluk, Tirunelveli District. Consisting of Ground Floor and Three Floors within the jurisdiction of Palayamkottai based on the inspection was done by the Assistant District Officer, Palayamkottai Fire and Rescue Station on 15/05/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This License is valid for THREE YEARS from the date of issue.

**CONDITIONS**

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained As per IS 1663:1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed

Signature valid  
Signed by District Officer  
Tirunelveli,  
Southern Region District Officer,  
District Department  
Date 20-May-2025 17:48:47  
Tirunelveli District

To: PSN Kamaraj Gents Hostel, Campus of PSN Institute of Technology & Science, R.S.No.4/1pt, 4/2pt, 4/3pt, 4/5A, 4/5B, 4/6B, 5/1pt, 5/2pt, 5/3pt, 5/4pt, 6/2pt, 6/3pt, 6/4pt, 6/5pt. Melathediyoor, Palayamkottai Taluk, Tirunelveli District.





**TAMIL NADU FIRE AND RESCUE SERVICES LICENCE**

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and  
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

District Office,  
Fire and Rescue Service,  
Tirunelveli District.  
Licence No: 7496/RFL/NMSB/2025  
Dated: 20/05/2025

**RENEWAL OF FIRE LICENCE**

Ref: Letter no:287155 from the PSN INSTITUTE OF  
TECHNOLOGY AND SCIENCE, Melathidivoor,  
Palayamkottai Taluk, Tirunelveli District, Dated:  
14/05/2025

\*\*\*\*\*

The Fire License is hereby **Issued** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for Educational Building in the name of PSN Institute of Technology And Science, R.S.No.4/1 pt, 4/2 pt, 4/3 pt, 4/5 A, 4/5B, 4/6B, 5/1 pt, 5/2 pt, 5/3 pt, 5/4 pt, 6/2 pt, 6/3 pt, 6/4 pt, 6/5 pt, Melathidivoor, Palayamkottai Taluk, Tirunelveli District. Consisting of Ground Floor and Three floors within the jurisdiction of Palayamkottai based on the inspection was done by the Assistant District Officer, Palayamkottai on 15/05/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEARS** from the date of issue.

**CONDITIONS**

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials and debris should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per IS 1646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be as per IS 17:53:19

**Signature valid**

Signed by: District Officer,  
Tirunelveli District Office,  
Southern Region, Palayamkottai.  
District Officer,  
Fire and Rescue Services



Tirunelveli District

To: PSN Institute of Technology And Science, R.S.No.4/1 pt, 4/2 pt, 4/3 pt, 4/5 A, 4/5B, 4/6B, 5/1 pt, 5/2 pt, 5/3 pt, 5/4 pt, 6/2 pt, 6/3 pt, 6/4 pt, 6/5 pt, Melathidiyoor, Palayamkottaik Taluk, Tirunelveli District.

**Signature valid**

Signed by: District Officer,  
Tirunelveli,  
Southern Region, District Officer,  
Home Department,  
Date:20-May-2025 17:53:19